

INTRACITY COMMUNICATION

March 14, 2007

Rhonda Clark - SPS

CARRIAGE WOODS – PRS2005-00616

SWALE GRADING

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<u>LOT</u>	<u>SWALE</u>	<u>EGL DEPTH</u> (FEET)
4	Exist B-B	0.76
5	Exist B-B	0.76
6	Exist B-B	0.76
6	C-C	0.47
7	C-C	0.47
8	C-C	0.47

If you have any questions, please contact me at 913-895-6182.

Berry Lutz
Senior Engineering Technician

- c: Tony Meyers, SupvCE
- Dan White, CISr
- Phelps Engineering, Inc.
- Damon Olson, Windsor Development II, L.L.C.
- Dev. file: Carriage Woods
- City website