

**INTRACITY COMMUNICATION**

September 27, 2006

Rhonda Clark - SPS

**MILLS FARM - FIRST PLAT**

**SWALE GRADING**

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<b><u>LOT</u></b>	<b><u>SWALE</u></b>	<b><u>EGL DEPTH</u></b> (FEET)
2	D-D	0.74
3	D-D	0.74
9	C-C	0.90
10	C-C	0.90
22	B-B	0.71
23	B-B	0.71
22	A-A	0.49
24	A-A	0.49
33	F-F	0.55

If you have any questions, please contact me at 913-895-6182.

Berry Lutz, ETsr

c: Phelps Engineering Inc.  
Developer: W S Development L.L.C.  
Subdivision Flood File: Mills Farm First Plat  
City website