

INTRACITY COMMUNICATION

April 15, 2011

Rhonda Clark - SPS

**MILLS FARM, EIGHTH PLAT
ESR2010-00014**

NOTE: *Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.*

MLO SET BY ENGINEER

The following lots are adjacent to large open stormwater conveyances which requires freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<u>Lots</u>	<u>MLO (All building Openings)</u>
188	969.4
189	986.7
190	986.3
191	985.3

If you have any questions, please contact me.



Berry Lutz, Senior Engineering Technician

c: Phelps Engineering, Inc
Tony Meyers, Manager Engineering Services
David Miller, Supervisory Civil Engineer
Jim Cannon, Construction Inspector, Senior
Mills Farm Development, LLC
Mills Farm Eighth Plat
City website