

INTRACITY COMMUNICATION

May 22, 2007

RHONDA CLARK – SPSS

**WOODS AT COLTON LAKE  
ESR 2006-00051**

**NOTE:** *Building Permits will not be issued until the Applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.*

**SWALE GRADING**

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<u>Lot</u>	<u>Section</u>	<u>EGL Depth (ft)</u>
1	A-A	0.89
2	A-A	0.89
3	F-F	0.62
4	F-F	0.62
15	B-B	0.57
16	C-C	0.43
17	C-C	0.43

**MLO SET BY ENGINEER**

The following lots are adjacent to large open stormwater conveyances which requires freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<b><u>Lot</u></b>	<b><u>MLO (All building Openings)</u></b>
7	1025.9
8	1025.9
9	1025.9
10	1025.9
11	1020.0
12	1019.7
13	1019.3
14	1018.8
15	1018.1
16	1018.0
17	1018.0

### **FOUNDATION INVESTIGATION**

The following lots are constructed over areas that require special foundation designs to minimize potential for geotechnical related problems. The foundation investigation must be submitted and approved prior to a footing inspection. An Engineered plot plan is NOT required for this condition.

<b><u>Lot</u></b>	<b><u>Condition</u></b>
14	Fill
15	Fill

If you have any questions, please contact me at 913-895-6182.

Berry Lutz, ETsr

mb

c: Tony Meyers, P.E. - SupvCE  
Schlagel & Associates, P.A.  
Riffe Home Building Company, 450 Winnebago Drive, Lake Winnebago, MO 64034  
Developer File: Woods at Colton Lake