

INTRACITY COMMUNICATION

November 30, 2009

Rhonda Clark – SPS

**WOODS AT COLTON LAKE - 3RD PLAT
ESR2008-00021**

NOTE: *Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.*

SWALE GRADING

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<u>LOT</u>	<u>SWALE</u>	<u>EGL DEPTH (FEET)</u>
16	A-A	0.78
17	A-A	0.78
18	A-A	0.78

If you have any questions, please contact me at (913) 895-6182.

Berry Lutz
Senior Engineering Technician

mb
c: Dave Rinne, RLS - Schlagel & Associates, P.A.
Tony Meyers, SupvCE
Ernie Longoria, CvE-II
Kenny Boone, Csl-II
The Woods at Colton Lake, L.L.C.
Woods at Colton Lake - 3rd Plat
City Website