

Planning and Development Services Department

**Project Address:** \_\_\_\_\_ **Project Name:** \_\_\_\_\_

**Permit #** \_\_\_\_\_ **Special Inspection Agency or Agent:** \_\_\_\_\_

This is to certify that I or qualified individual(s) working under my direction inspected and/or tested the following items in accordance with the City of Overland Park Design and Construction Standards, approved plans and specifications. I have found that the work is in substantial compliance with the City of Overland Park Design and Construction Standards, approved plans and specifications.

**Check appropriate items for Extended Wet Detention Ponds:**

- |  |   |
|--|---|
| <input type="checkbox"/> <b>FINAL GRADES, LOCATIONS, VOLUME CONFORM WITH CONSTRUCTION PLANS</b>                      | <input type="checkbox"/> <b>PRETREATMENT DEVICE INSTALLED AT LOCATION/ELEVATION SHOWN ON PLANS</b>          |
| <input type="checkbox"/> <b>LITTORAL BENCH EXTENDS AT LEAST 10' INWARD FROM PERIMETER; SLOPE DOES NOT EXCEED 6:1</b> | <input type="checkbox"/> <b>OVERFLOW INSTALLED AT LOCATION/ELEVATIONS SHOWN ON PLANS</b>                    |
| <input type="checkbox"/> <b>TRASH RACKS PROVIDED ON OUTLET STRUCTURE</b>   | <input type="checkbox"/> <b>EMERGENCY SPILLWAY MEETS DIMENSIONS, ELEVATION, AND LOCATION SHOWN ON PLANS</b> |
| <input type="checkbox"/> <b>INLET WORKS EROSION CONTROL INSTALLED AT LOCATION/ELEVATIONS SHOWN ON PLANS</b>          | <input type="checkbox"/> <b>PLANT MATERIALS MEET SIZE, DENSITY, TYPE, AND LOCATION AS SHOWN ON PLANS</b>    |
| <input type="checkbox"/> <b>STAFF GAGE OR VERTICAL MARKER PROVIDED FOR SEDIMENT FOREBAY</b>                          | <input type="checkbox"/> <b>PIPE DISCHARGES AT LEAST 6" ABOVE NORMAL POOL ELEVATION</b>                     |
| <input type="checkbox"/> <b>OTHER</b> _____  |   |

**Professional Seal** \_\_\_\_\_

**Signature** \_\_\_\_\_ **Date** \_\_\_\_\_

Submit to: Engineering Services Division  
 Planning and Development Services Department  
 City of Overland Park,  
 8500 Santa Fe Drive,  
 Overland Park, KS 66212  
 eod@opkansas.org  
 Phone: 913-895-6223 Fax: 913-895-5016