

INTRACITY COMMUNICATION

September 17, 2012

Rhonda Clark – SPS

**THE FARM AT GARNET HILL
ESR #2008-00022 PIP #2008-00007**

NOTE: Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.

SWALE GRADING

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<u>LOT</u>	<u>SWALE</u>	<u>EGL DEPTH (FEET)</u>
4	D-D	0.78
5	D-D	0.78
5	C-C	0.68
6	C-C	0.68
9	E-E	0.78
10	F-F	0.94
11	G-G	0.80
11	H-H	weir
12	G-G	0.80
12	H-H	weir
13	F-F	0.94
14	E-E	0.78

MLO SET BY ENGINEER

The following lots are adjacent to large open stormwater conveyances which require freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<u>LOT</u>	<u>MLO (All Building Openings)</u>
1	973.8
11	974.5
19	964.2
20	963.4

FOUNDATION INVESTIGATION

The following lots are constructed over areas that require special foundation designs to minimize potential for geotechnical related problems. The foundation investigation must be submitted and approved prior to a footing inspection. An Engineered plot plan is NOT required for this condition.

<u>LOT</u>	<u>CONDITION</u>
4	Fill
5	Fill
9	Fill
19	Fill

If you have any questions, please contact me.

Ernie Longoria, P.E.
Civil Engineer II

c: Phelps Engineering, Inc., Tim Tucker, P.E.
Tony Meyers, Manager, Engineering CE
Dan White, SrCI
Garnet Hill, LLC, 10823 W 164th St., Overland Park, KS, 66062, 913-681-1230
The Farm At Garnet Hill, First Plat
City website