

**CITY OF OVERLAND PARK      PLANNING AND DEVELOPMENT SERVICES**

**INTRACITY COMMUNICATION**

November 20, 2018

Rhonda Clark – SPS

**SUBDIVISION NAME – MISSION RANCH 2ND PLAT  
PIP2017-00108**

***NOTE: Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.***

***NOTE: Prior to Building Permits being issued, a Water Service Availability letter from WaterOne must be submitted to Building Safety.***

**SWALE GRADING**

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<b><u>LOT</u></b>	<b><u>SWALE</u></b>	<b><u>EGL DEPTH (FEET)</u></b>
54	E-E	0.75
55	E-E	0.75
57	D-D	0.75
57	C-C	0.75
58	C-C	0.75
59	C-C	0.75
60	B-B	0.67
61	A-A	0.62
62	A-A	0.62
69	C-C	0.75
70	B-B	0.67
71	A-A	0.62
72	A-A	0.62

## **BERM GRADING**

The following lots include berms designed to direct stormwater runoff. An engineered plot plan is required for these lots that show preserving or constructing berms as shown on the subdivision as-built grading plan.

### **LOT**

54  
55  
57  
59  
60  
62  
69  
70  
72

## **MLO SET BY ENGINEER**

The following lots are adjacent to large open stormwater conveyances which require freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

### **LOT**

56

### **MLO (All Building Openings)**

964.0

## **LOT GRADING**

The following lots require specific grading to ensure proper drainage paths between lots. An engineered plot plan is required for these lots which show the drainage paths based upon grading specified by the Engineer.

### **Lot**

Mission Ranch 2nd Plat  
November 20, 2018  
Page 3

48  
49  
50  
53  
54  
55  
60  
65  
66  
67  
68  
74  
78  
79

If you have any questions, please contact me.

*Stephanie Byard*

Stephanie Byard  
Engineering Technician II

c: Tim Tucker, P.E. Phelps Engineering Inc.  
Tony Meyers, P.E. Engineering Services Inspector Supervisor  
Brandon Melius, Inspector  
Jeff Hunt - Supervisor, Public Works Maintenance  
Mission Road Partners, LLC  
Mission Ranch 1st Plat - Subdivision Flood File  
City website