

**Planning and Development Services Department**

**Project Address:** \_\_\_\_\_ **Project Name:** \_\_\_\_\_

**Permit #** \_\_\_\_\_ **Special Inspection Agency or Agent:** \_\_\_\_\_

This is to certify that I or qualified individual(s) working under my direction inspected and/or tested the following items in accordance with the City of Overland Park Design and Construction Standards, approved plans and specifications. I have found that the work is in substantial compliance with the City of Overland Park Design and Construction Standards, approved plans and specifications.

**Check appropriate items for Rain Gardens:**

- |   |   |
|---|---|
| <input type="checkbox"/> SOIL AMENDMENTS MEET REQUIREMENTS<br>(IF AMENDMENTS REQUIRED)  | <input type="checkbox"/> FINAL GRADES, LOCATIONS, VOLUME<br>CONFORM WITH CONSTRUCTION PLANS   |
| <input type="checkbox"/> PLANT MATERIALS MEET SIZE, DENSITY, TYPE<br>AND LOCATION AS SHOWN ON PLANS                           | <input type="checkbox"/> OVERFLOW INSTALLED AT LOCATION/<br>ELEVATIONS SHOWN ON PLANS   |
| <input type="checkbox"/> TYPE AND THICKNESS OF MULCH<br>INSTALLED PER PLANS   | <input type="checkbox"/> MULCH NETTING INSTALLED PER<br>MANUFACTURER'S SPECIFICATIONS   |
| <input type="checkbox"/> PERCOLATION RATE TESTED PRIOR TO START OF<br>CONSTRUCTION; RESULTS SUBMITTED TO CITY<br>STAFF        | <input type="checkbox"/> MINIMUM 6" FREEBOARD BETWEEN<br>OVERFLOW ELEVATION AND LOWEST<br>ADJACENT PAVEMENT ELEVATION   |
| <input type="checkbox"/> ALTERNATE DISCHARGE LOCATION IDENTIFIED<br>FOR TRENCH DRAIN CONNECTION IF FACILITY<br>FAILS TO DRAIN | <input type="checkbox"/> PERCOLATION RATE TESTED PRIOR TO PLANT<br>INSTALLATION; PERCOLATION RATE SUFFICIENT<br>TO INFILTRATE ENTIRE FACILITY WITHIN 48 HOURS |
| <input type="checkbox"/> OTHER _____  |   |

**Professional Seal** \_\_\_\_\_

**Signature** \_\_\_\_\_ **Date** \_\_\_\_\_

Submit to: Engineering Services Division  
 Planning and Development Services Department  
 City of Overland Park  
 8500 Santa Fe Drive  
 Overland Park, KS 66212  
 eod@opkansas.org  
 Phone: 913-895-6223 Fax: 913-895-5016