

CITY OF OVERLAND PARK PLANNING AND DEVELOPMENT SERVICES

INTRACITY COMMUNICATION

February 21, 2018

Rhonda Clark – SPS

**TERRYBROOK FARMS, 6TH PLAT (REPLAT)
PIP2017-00022**

NOTE: Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.

SWALE GRADING

The following lots include, or are adjacent to engineered swales designed for purposes of stormwater conveyance. An engineered plot plan is required for these lots in conformance with City requirements.

Minimum Low Openings must be a minimum of 1 foot above the 100-year storm energy grade line as measured perpendicular to the swale.

<u>LOT</u>	<u>SWALE</u>	<u>EGL DEPTH (FEET)</u>
196	F-F	0.31

BERM GRADING

The following lots include berms designed to direct stormwater runoff. An engineered plot plan is required for these lots that show preserving or constructing berms as shown on the subdivision as-built grading plan.

LOT

195
197

MLO SET BY ENGINEER

The following lots are adjacent to large open stormwater conveyances which require freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<u>LOT</u>	<u>MLO (All Building Openings)</u>
193	1036.3
194	1036.3
195	1036.3

If you have any questions, please contact me.



Stephanie Byard, Engineering Technician II

- c: Tim Tucker, P.E., Phelps Engineering
Pam Fortun, P.E., Review Engineer
David Miller, P.E., Engineering Services Inspector Supervisor
Tony Meyers, P.E., Manager, Engineering Services
Brandon Melius, Inspector
Jeff Hunt - Supervisor, Public Works Maintenance
Terrybrook Partners, LLC, Developer
Terrybrook Farms 6th Plat Flood File
City website