

**CITY OF OVERLAND PARK      PLANNING AND DEVELOPMENT SERVICES**

**INTRACITY COMMUNICATION**

June 23, 2016

Rhonda Clark – SPS

**WHEATLEY VILLAGE  
ESR #2015-00086**

***NOTE: Building Permits will not be issued until the applicant produces a Sanitary Sewer Connection Permit from Johnson County Wastewater.***

**MLO SET BY ENGINEER**

The following lots are adjacent to large open stormwater conveyances which require freeboard for all building openings and tops of foundation walls. An engineered plot plan is required for these lots which show the minimum low opening established on the subdivision as-built grading plan and actual proposed building openings and top of foundation wall elevations.

<b><u>LOT</u></b>	<b><u>MLO (All Building Openings)</u></b>
1	973.0
2	973.0
3	973.0
4	973.0
5	973.0

If you have any questions, please contact me.



Ernie Longoria, P.E.  
Civil Engineer, Sr.

- c: John Becker, P.E. - Schlagel & Associates
- Tony Meyers, P.E. - Manager, Engineering Services
- David Miller, P.E. - Supervisory Civil Engineer
- Dan White - Construction Inspector, Sr.
- Michael Menghini - Covenant Homes, LLC
- Subdivision Flood File
- City website